



Structural Design
(801) 876-3501

Date: May 8, 2019

Idaho Falls Building Department
Attn: Builder Official

Subject: Footing Change, The Falls at Snake River Landing Building 2 – 24 Unit

The purpose of this letter is to provide my approval of the following change on Building 2 of the Falls at Snake River Landing Apartments located in Idaho Falls, ID. The four 30" sonotubes shown on the plan for the front corridor posts may be replaced with four 36"x36"x10" spot footings with (4) #4 bars each way and 24" diameter sonotubes with (9) #4 bars vertical and #3 stirrups @ 8" o.c. w/ (3) #3 stirrups within 3" of the top. No other structural changes are required.

Please feel free to call with any questions or concerns.

Respectfully,

Helena N. Dopita, P.E.

