REScheck Software Version 4.6.2

Compliance Certificate

Project LINDEN TRAILS PLAN A

Energy Code:	**2012 IECC**
Location:	**Idaho Falls, Idaho**
Construction Type:	**Single-family**
Project Type:	**New Construction**
Conditioned Floor Area:	**5,812 ft2**
Glazing Area	**9%**
Climate Zone:	**6 (7918 HDD)**
Permit Date:	
Permit Number:	

Construction Site:

Owner/Agent:

Designer/Contractor:
MIKE
ROTH PROPERTIES

Compliance: Passes using UA trade-off

Compliance: **0.4% Better Than Code** Maximum UA: **560** Your UA: **558**

The % Better or Worse Than Code Index reflects how close to compliance the house is based on code trade-off rules.
It DOES NOT provide an estimate of energy use or cost relative to a minimum-code home.

Envelope Assemblies

Assembly	Gross Area or Perimeter	Cavity R-Value	Cont. R-Value	U-Factor	UA
Ceiling 1: Flat Ceiling or Scissor Truss	2,924	55.0	0.0	0.024	70
Wall 1: Wood Frame, 16" o.c.	4,195	22.0	0.0	0.056	209
Door 1: Solid	82			0.140	11
Door 2: Glass	82			0.280	23
Window 1: Vinyl/Fiberglass Frame:Double Pane with Low-E	303			0.280	85
Floor 1: Slab-On-Grade:Unheated Insulation depth: 3.0'	228		10.0	0.702	160

Compliance Statement: The proposed building design described here is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed building has been designed to meet the 2012 IECC requirements in RES*check* Version 4.6.2 and to comply with the mandatory requirements listed in the RES*check* Inspection Checklist.

Name - Title

Signature

Date